



AGA CERTIFIED PRODUCT

JAS-ANZ



www.jas-anz.org/register

Certificate Holder: **TECHRITE CONTROLS AUSTRALIA PTY LTD**

ABN/ACN No. (if applicable): **006 959 495**

Manufacturer: **G. BEE GMBH**

Agent (if applicable): **N/A**

Type of Component: **TYPE 1 MANUAL SHUT-OFF ISOLATING BALL VALVES (FLANGED END CONNECTIONS)
MWP 1600 kPa
Temperature Range -20°C to +60°C**


Model No. & Description: **G BEE (DUNGS)
KSN 75 SERIES
(DN-mm 25, 32, 40, 65, 80, 100, 125, 150)**
(Refer www.aga.asn.au for more details)

Relevant Standard(s): **AS 4617 - 2004**

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

This Certificate is issued on the express conditions that:

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) This Certificate remains the property of the AGA; and
- (iii) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.



Reviewing Officer

Certificate Authorised

Certificate first issued: **24 AUGUST 2010**

Certificate No: **7697**

This copy valid from: **24 AUGUST 2010**

Refer specification issue: **01**